

Fischer-Tropsch Fuels from Coal and Biomass

T.G. Kreutz, E.D. Larson, G. Liu, and R.H. Williams
Princeton Environmental Institute
Princeton University
rwilliam@princeton.edu

Prepared for presentation at
25th Annual International Pittsburgh Coal Conference
29 September - 2 October 2008
Pittsburgh, Pennsylvania

Acknowledgments

The work described here was supported by Princeton University's Carbon Mitigation Initiative and its sponsors (BP and the Ford Motor Company), Princeton University's Next Generation Aircraft Fuels Program, sponsored by NetJets Inc., and The William and Flora Hewlett Foundation. Also, results were derived in part from work funded by the National Academy of Sciences, with support from the National Academy of Engineering, National Research Council, the U.S. Department of Energy, General Motors, Intel Corporation, Kavli Foundation, and the Keck Foundation.


The authors received helpful commentary and discussion from many individuals during the research for and writing of this paper. Thanks especially to David Gray, Chuck White, and Glen Tomlinson (Noblis), Tom Tarka, John Wimer, Ken Kern, and Michael Reed (NETL), Robert Socolow (Princeton University), and Jim Katzer and Sheldon Kramer (independent).

FTL Analytical Framework

- Consistent and detailed analytical framework applied to compare 16 FTL process designs using coal and/or biomass as feedstocks.
- Aspen Plus for estimating mass/energy/carbon balances and then using these to estimate CAPEX, component by component.
- “Nth” plant ($N \approx 5$) performance/cost estimates
- Key technology components:
 - GE quench gasifier for coal
 - GTI ($O_2 + steam$)-blown fluid-bed gasifier + tar cracking for biomass
 - Rectisol for acid gas removal
 - low-temperature slurry-phase FT reactor (*Fe catalyst*)
 - Onsite FT refining to **finished diesel/jet fuel and high-octane gasoline**
 - power island with:
 - steam turbine power for FT recycle cases that maximize FTL production
 - combined cycle power with “F” class gas turbines for FTL once-through cases
- GREET model in estimating fuel-cycle-wide GHG emissions

Capex Estimates

- Aspen mass/energy/carbon balance simulations used as basis for power-law scaling of Capex for:
 - Most major plant areas: from NETL coal power study (2007).*
 - Biomass gasification: from Fluor studies (1984,1985) + NETL coal power study (2007)
 - F-T island: Bechtel work** from 1990s—including upgrading to finished fuels
- Costs include BOP, indirects, and contingencies
- Nth plant design philosophy (for equipment train sizes and costs)
- All costs escalated to mid-year 2007\$ using *Chemical Engineering Plant Cost* index.



* *Cost and Performance Baseline for Fossil Energy Plants: Volume 1: Bituminous Coal and Natural Gas to Electricity*, DOE/NETL-2007/1281, Rev. 1, August 2007, National Energy Technology Laboratory.

** Bechtel, *Baseline Design/Economics for Advanced Fischer-Tropsch Technology*, report under contract DE-AC22-91PC90027, April 1998, Federal Energy Technology Center.

Feedstock Assumptions

Feedstock	Type	Delivered price, \$/GJ _{HHV}
Coal	Bituminous, Illinois #6	1.71
Biomass	Switchgrass/mixed prairie grasses	5.0


Acronyms

CTL	Coal to finished FTL fuels (diesel/jet, gasoline) and electricity
BTL	Biomass to finished FTL fuels (diesel/jet, gasoline) and electricity
CBTL	Coal + biomass to finished FTL fuels (diesel/jet, gasoline) and electricity
RC	FTL synthesis with recycle (RC) of unconverted syngas for maximum FTL output
OT	FTL synthesis with once through (OT) synthesis; unconverted syngas used to make coproduct power in a combined cycle
OTA	Autothermal reformer and extra CO ₂ capture equipment added to OT system downstream of FT synthesis to increase CO ₂ capture/storage
V	Coproduct CO ₂ is vented
CCS	Coproduct CO ₂ is captured and piped to underground storage site
S	Biomass feedstock is mixed prairie grasses grown on C-depleted soils. Soil/root C buildup as biomass C storage mechanism complements underground storage of supercritical CO ₂

Sixteen Process Designs

CTL-RC-V	50,000 barrels/day of finished FTL fuels (diesel/jet and gasoline)
CTL-RC-CCS	Same coal input and same FTL outputs as CTL-RC-V
CTL-OT-V	Same coal input as CTL-RC-V
CTL-OT-CCS	Same coal input as CTL-RC-V, same FTL outputs as CTL-OT-V
CTL-OTA-CCS	Same coal input as CTL-RC-V, same FTL outputs as CTL-OT-V
BTL-RC-V	CBIR (<i>Common Biomass Input Rate = 10⁶ dry metric tonnes/yr processed</i>)
BTL-RC-CCS	CBIR, same FTL outputs as BTL-RC-V
CBTL-RC-V	CBIR, same coal input, FTL outputs as CBTL-RC-CCS
CBTL-RC-CCS	CBIR, coal/biomass ratio that yields FTL with zero GHG emission rate
CBTL-OT-V	CBIR, same coal input, FTL outputs as CBTL-OT-CCS
CBTL-OT-CCS	CBIR, coal/biomass ratio that yields FTL with zero GHG emission rate
CBTL2-OT-CCS	CBIR, same FTL outputs as CTL-OT-CCS
CBTL-OTS-CCS	CBIR, coal/biomass ratio that yields FTL with zero GHG emission rate
CBTL-OTA-V	CBIR, same coal input, FTL outputs as CBTL-OTA-CCS
CBTL-OTA-CCS	CBIR, coal/biomass ratio that yields FTL with zero GHG emission rate
CBTL-OTAS-CCS	CBIR, coal/biomass ratio that yields FTL with zero GHG emission rate

Some CTL Options: V vs CCS; RC vs OT




Minimum GHG emissions price to induce CCS ———

- η_{HHV} = efficiency of making FTL + electricity (HHV basis)
- GHGI (*GHG emissions index*) = FTL GHG emissions relative to emissions for COPD when electricity assigned C-IGCC-CCS GHG emission rate
- CI (*capture index*) = CO₂ captured as fraction of feedstock C not in FTL
- BECOP = Breakeven crude oil price (\$/barrel) at \$0/t of CO_{2eq}

System	Outputs	η_{HHV}	GHGI	CI	CAPEX (\$10 ⁹)	BECOP
CTL-RC-V	50,000 B/D + 427 MW _e	0.500	2.2	0	4.88	56
CTL-RC-CCS	50,000 B/D + 317 MW _e	0.486	1.0	0.78	4.95	63
CTL-OT-V	36,700 B/D + 1279 MW _e	0.493	2.8	0	4.41	40
CTL-OT-CCS	36,700 B/D + 1075 MW _e	0.467	1.3	0.68	4.60	55

Electric Generation Cost vs GHG Emissions Price





- For FTL systems coproduct electricity is valued at **average electric grid price**
- Minimum GHG emissions price needed to induce CCS for coal power depends on whether electricity demand is **growing** or **not**
- (IGCC/PC costs estimated using same methodologies as for FTL systems)

Minimum GHG emissions price to induce CCS for coal power if electricity demand is:
growing ———— constant or declining ————

Marginal electric generation efficiency (MEGE) for CTL-OT-V \gg η_{LHV} for C-IGCC-V


- **FTL = 1000 MW**
- $\Delta E_{\text{coal}} = 3152.2 - 2309.7 = 842.5 \text{ MW}$
- $\Delta \text{Power} = 554.5 - 135.7 = 418.8 \text{ MW}_e$
- **MEGE = 49.7%**
- η_{LHV} for C-IGCC-V = **39.3%**




Marginal electric generation efficiency (MEGE) for CTL-OT-CCS $\gg \eta_{LHV}$ for C-IGCC-CCS

- **FTL = 1000 MW**
- $\Delta E_{\text{coal}} = 3152.3$
- $- 2309.7 = 842.6 \text{ MW}$
- $\Delta \text{Power} = 465.8$
- $- 100.7 = 365.1 \text{ MW}_e$
- **MEGE = 43.3%**
- η_{LHV} for C-IGCC-CCS = **33.2%**


CTL-OT-CCS Energy Flows



CTL-RC-CCS Energy Flows



Reducing GHG emissions for CTL-OT systems via ATR




Minimum GHG emissions price to induce CCS

- Adding ATR reduces GHGI to < 1 but...
- BECOP is much higher
- Minimum GHG emissions price needed to induce CCS ~ same as for C-IGCC-CCS when electricity demand is rising

System	Outputs	η_{HHV}	GHGI	CI	CAPEX (\$10 ⁹)	BECOP
CTL-OT-V	36,700 B/D + 1279 MW _e	0.493	2.8	0	4.41	40
CTL-OT-CCS	36,700 B/D + 1075 MW _e	0.467	1.3	0.68	4.60	55
CTL-OTA-CCS	36,700 B/D + 818 MW _e	0.433	0.9	0.85	5.10	73


Energy Penalty for CO₂ Capture



Value of Energy Penalty for CO₂ Capture @ \$60MWh (\$/t)
 Value of Energy Penalty (as % of Total Capture Cost)

- **CTL-RC-CCS:** CO₂ compression is only penalty
- **CTL-OT-CCS:** N₂ compression for NO_x control accounts for most of added penalty
- **CTL-OTA-CCS:** Penalties (*beyond CO₂ compression penalty*) consist mainly of:
 - Huge loss of gross power output from chemical energy loss via syngas burning for ATR
 - Electric energy penalty (*ASU*) for providing O₂ to ATR
 - About same level of N₂ needed per unit of GT expander output as for CTL-OT-CCS


CO₂ Capture Cost



Capture cost penalty for CTL-OT-CCS is:

- 48% of penalty for CTL-OTA-CCS
- 60% of penalty for IGCC-CCS
- 35% of post-combustion capture penalty for PC-CCS (*not shown*)

Reducing CTL-OT emissions by cofiring some biomass




- With 9% biomass feed, GHGI \rightarrow 1.0
- BECOP for CBTL2-OT-CCS << than for CTL-OTA-CCS
- CBTL2-OT-CCS offers early route for decarbonizing coal power

Minimum GHG emissions price to induce CCS



System	Outputs	η_{HHV}	GHGI	CI	BECOP
CTL-OT-CCS	36,700 B/D + 1075 MW _e	0.467	1.3	0.68	55
CTL-OTA-CCS	36,700 B/D + 818 MW _e	0.433	0.9	0.85	73
CBTL2-OT-CCS (9% bio)	36,700 B/D + 1113 MW _e	0.469	1.0	0.68	59

Dispatch competition: CBTL2-OT-CCS as generator of decarbonized power vs old coal power plants




@ \$27/t CO_{2eq} CBTL2-OT-CCS plants could beat old coal power plants in economic dispatch at crude oil prices down to ~ \$7 a barrel

\rightarrow This/other CBTL-OT-CCS options very effective in backing out old coal plants



CBTL-OTS-CCS



Assumed feedstock: mixed prairie grasses (**MPGs**) grown on land not suitable for food production (e.g., *CRP land*) with C-depleted soils

Assumed 30-y soil/root C storage rate: 0.3 tC/dt of MPG (Tilman et al., 2006).


GHGI = 0 is realized with less biomass input than in CBTL-OT-CCS case

System	Output	η_{HHV}	GHGI	CI	BECOP
CBTL-OTS-CCS (24% bio)	13,000 B/D + 406 MW _e	0.467	0.0	0.67	83

FTL via CBTL with CCS vs Alternatives

- Assume deployment of CBTL systems with CCS providing decarbonized power & FTL to displace crude oil derived products + existing coal power
- Assume GHG emissions price = \$50/t CO_{2eq} under serious C-policy
- **Each set of 100 CBTL-OT-CCS plants (each plant consuming 10⁶ dt/y of biomass) could:**
 - Provide at plant gate FTL w/GHGI = 0 @ **\$2.0/gge** and electricity @ **\$92/MWh**
 - Net coal = **22%** of coal for CTL-RC-CCS plants offering FTL w/GHGI = 1.0
 - Require **59%** as much lignocellulosic biomass as would be required for *future* cellulosic ethanol plants providing same amount of gasoline-equivalent fuel
 - Provide decarbonized power equivalent to **11%** of US coal power in 2007
- **Each set of 100 CBTL-OTS-CCS plants (each plant consuming 10⁶ dt/y of biomass) could:**
 - Provide at plant gate FTL w/GHGI = 0 @ **\$1.7/gge** and electricity @ **\$92/MWh**
 - Net coal = **50%** of coal for CTL-RC-CCS plants offering FTL w/GHGI = 1.0
 - Require **37%** as much lignocellulosic biomass as would be required for *future* cellulosic ethanol plants providing same amount of gasoline-equivalent fuel
 - Provide decarbonized power equivalent to **16%** of US coal power in 2007

LEAST-COSTLY FTL OPTIONS



Breakeven crude oil price (\$/barrel)

FTL pump price (\$/gge...assuming \$0.70/gge markup for distribution/retail taxes)

FTL GHG emission rate relative to rate for crude oil products displaced

% biomass in feedstock (HHV basis)

Conclusion

- Largely because of their high marginal power generation efficiencies, OT systems are more cost-competitive than RC systems in making syngas
- OT CBTL plants with CCS offer attractive opportunity for decarbonizing liquid fuels and power generation simultaneously
 - Require ¼ to ½ as much *net coal* for making syngas as CTL-RC-CCS plants
 - Require ½ or less lignocellulosic biomass than for making cellulosic ethanol
- OT CBTL “must-run” power plants with CCS would be highly competitive in economic dispatch and thus able to back out existing coal power plants
- Such plants fueled with modest biomass inputs offer early route to CCS for power because CO₂ capture costs are much less than for stand-alone power plants
 - Strong candidates for 3-10 megascale integrated CCS projects during next decade to:
 - Establish gigascale viability of CCS as C-mitigation option
 - Establish strong scientific/engineering basis for regulations of subsequent commercial CO₂ storage projects
 - Competitive options for providing CO₂ for enhanced oil recovery projects
- Investments in OT CBTL plants with CCS would be shielded against financial risk of oil price collapse by a strong C-mitigation policy (*manifest by GHG emissions value ~ \$50/t CO_{2eq}*)