

## Co-Production of Hydrogen and Electricity from Fossil Fuels with CO<sub>2</sub> Capture

Robert H. Williams, Robert H. Socolow, Thomas Kreutz,  
Stefano Consonni, and Paolo Chiesa  
Princeton Environmental Institute  
Princeton University

Second Annual Conference on Carbon Sequestration  
Washington, DC  
5-8 May 2003

### *Large-Scale Production of H<sub>2</sub> from Fossil Fuels*

*Four Related Papers Prepared Under Princeton University's  
Carbon Mitigation Initiative Presented Here*

	Natural Gas	Coal & Residuals Gasification
CO <sub>2</sub> Venting	Almost all H <sub>2</sub> produced today	Refineries, chemicals, NH <sub>3</sub> production in China 2) “Conventional technology”
CO <sub>2</sub> Capture	1) FTR vs. ATR with CC	2) “Conventional technology” 3) Membrane reactors 4) <b>Overview</b>


## Scope of Presentation

- Electricity from coal IGCC
- H<sub>2</sub> + electricity coproduct from coal
  - Conventional technology (like coal IGCC)
  - H<sub>2</sub> separation membrane reactor
- H<sub>2</sub> + electricity coproduct from natural gas
  - Fired tubular reactors (FTRs) (a.k.a. steam reformers)
  - O<sub>2</sub>-blown autothermal reactors (ATRs)
- Effects of gasifier pressure on H<sub>2</sub> production from coal
- Gasifiers with synthesis gas coolers (syncoolers) vs. quench...comparing efficiencies and costs
- Cooled vs. uncooled turbines for H<sub>2</sub> separation membrane reactors
- Coal/natural gas competition in climate-constrained world
- CO<sub>2</sub> storage demo roles for gasification-based H<sub>2</sub> while awaiting the H<sub>2</sub> economy
- Outlook for electricity and H<sub>2</sub> via coal gasification in climate-constrained world

## WHY COAL?


- Coal resources abundant globally
- Much of global population (*e.g., China, India*) heavily coal-dependent
- Coal prices low and not volatile
- Gasification:
  - near-zero emissions of air pollutants/GHGs
  - Potentially very attractive costs for coal-derived H<sub>2</sub> with CO<sub>2</sub> capture/storage
- Residual environmental, health, safety problems of coal mining

## Benchmark: Coal IGCC Electricity with CO<sub>2</sub> Capture (70 bar gasifier)




- 362 MW<sub>e</sub> [ $\eta = 34.9\%$  (HHV)] @ \$1807/kW<sub>e</sub> and 6.4¢/kWh [includes \$5/t CO<sub>2</sub> (0.4¢/kWh) for CO<sub>2</sub> transport and underground aquifer storage]
- 390 MW<sub>e</sub> ( $\eta = 40.8\%$ ) @ \$1394/kW<sub>e</sub> and 4.7 ¢/kWh if CO<sub>2</sub> vented

## H<sub>2</sub> Production from Coal with CO<sub>2</sub> Capture (70 bar gasifier)



- 1265 MW<sub>h</sub> H<sub>2</sub> [ $\eta = 67.0\%$  (HHV)] @ \$7.3/GJ [includes \$5/t CO<sub>2</sub> (\$0.6/GJ) for CO<sub>2</sub> transport and underground aquifer storage] + 39 MW<sub>e</sub> electricity coproduct
- 1265 MW<sub>h</sub> H<sub>2</sub> ( $\eta = 69.7\%$ ) @ \$6.2/GJ + 78 MW<sub>e</sub> electricity coproduct w/CO<sub>2</sub> vented

## H<sub>2</sub> Separation Membrane Reactor System (70 bar gasifier)




- Employ a H<sub>2</sub> permeable, thin film (10 μm), 60/40 % Pd/Cu (sulfur tolerant) dense metallic membrane, configured as a WGS membrane reactor
- 1000 MW<sub>h</sub> H<sub>2</sub> (η = 69.1%) @ \$6.7/GJ [includes includes \$5/t CO<sub>2</sub> (\$0.7/GJ) for CO<sub>2</sub> transport and underground aquifer storage] + 18 MW<sub>e</sub> electricity coproduct—assuming co-storage of SO<sub>2</sub> and CO<sub>2</sub>

## Electricity and H<sub>2</sub> Costs for Coal with CO<sub>2</sub> Capture + Storage (70 bar Gasifier, Conventional Technology)

	CO <sub>2</sub> vented	CO <sub>2</sub> captured and stored	
<b>Electricity only</b>			
Output	390 MW <sub>e</sub>	362 MW <sub>e</sub>	-
Electricity Cost	4.7 ¢/kWh	6.4 ¢/kWh	-
Avoided cost (for capture only)	-	\$24 (\$18)/t CO <sub>2</sub>	-
<b>H<sub>2</sub> + electricity coproduction systems</b>			
H <sub>2</sub> output (HHV)	1265 MW <sub>h</sub>	1265 MW <sub>h</sub>	268 MW <sub>h</sub>
Electricity output	78 MW <sub>e</sub>	39 MW <sub>e</sub>	349 MW <sub>e</sub>
Electricity value	4.7 ¢/kWh	6.4 ¢/kWh	6.4 ¢/kWh
H <sub>2</sub> cost (HHV)	\$6.2/GJ	\$7.3/GJ	\$5.5/GJ
Avoided cost (for capture only)	-	\$12 (\$6)/t CO <sub>2</sub>	\$15 (\$9)/t CO <sub>2</sub>

- No thermodynamic advantage to coproducing H<sub>2</sub>/electricity (*unlike CHP*)
- Making large amounts of coproduct electricity is worthwhile only for high electricity prices
- Coproduction with power output ~ stand-alone power plants + modest H<sub>2</sub> output → H<sub>2</sub> cost with CO<sub>2</sub> capture/storage < for plants producing mainly H<sub>2</sub> with CO<sub>2</sub> vented  
if electricity value = electricity cost for stand-alone IGCC with CO<sub>2</sub> capture/storage

### Breakdown of Incremental Capital Cost for CO<sub>2</sub> Capture



- Incremental cost for CO<sub>2</sub> capture is less for hydrogen than electricity because much of the equipment is already needed for a H<sub>2</sub> plant.

### Electricity and H<sub>2</sub> Coproduction for Natural Gas

- CMI modeling of H<sub>2</sub> from NG embryonic
- Initial focus on thermodynamic modeling of
  - Fired tubular reformers (FTRs)—i.e., steam reformers (@ 25 bar, 850 °C)
  - Oxygen-blown autothermal reactors (ATRs) (@ 70 bar, 950 °C)
- Industrial interest in H<sub>2</sub> for chemical/refining industry needs usually focused on systems that produce zero net electricity (*just enough to meet onsite needs*)
- If H<sub>2</sub> is produced at large scales for energy in climate-constrained world, coproduction of electricity via combined cycles might sometimes be considered:
  - Electricity manufacture from some of produced H<sub>2</sub> can sometimes lead to high marginal efficiencies ( $\eta > 80\%$ ) in converting H<sub>2</sub> to electricity
    - For FTR + CC coproduction carbon removal rates are not higher than ~ 50%
    - For ATRs operated with steam/carbon ratios  $\geq 1.5$ , carbon removal rates higher than 80% can be realized
  - Whether such opportunities can be cost justified remains to be determined

<b>CO<sub>2</sub> Storage vs Co-Storage of CO<sub>2</sub> and H<sub>2</sub>S or SO<sub>2</sub></b> (70 bar coal gasifier with quench)			
	CO <sub>2</sub> vented	S recovery, CO <sub>2</sub> stor	CO <sub>2</sub> + H <sub>2</sub> S co-stor
Elect gen cost, conv tech	4.7 ¢/kWh	6.4 ¢/kWh	6.0 ¢/kWh
Avoided cost ( <i>capture only</i> )	-	\$24 (\$18)/t CO <sub>2</sub>	\$18 (\$13)/t CO <sub>2</sub>
H <sub>2</sub> prod cost, conv tech	\$6.2/GJ	\$7.3/GJ	\$6.7/GJ
Avoided cost ( <i>capture only</i> )	-	\$12 (\$6)/t CO <sub>2</sub>	\$6 ( <b>\$0.5</b> )/t CO <sub>2</sub>
		FGD, CO <sub>2</sub> stor	CO <sub>2</sub> + SO <sub>2</sub> co-stor
H <sub>2</sub> prod cost, Pd/Cu membrane		\$7.2/GJ	\$6.7/GJ
Avoided cost ( <i>capture only</i> )		\$10 (\$4)/t CO <sub>2</sub>	\$5 ( <b>-\$0.4</b> )/t CO <sub>2</sub>

- Carbon-Sulfur co-capture/co-storage leads to lower costs, mainly due to reduced capital requirements—**avoided cost for capture is near zero**
- Potential risks of co-storage options should be studied to determine feasibility of these options

<b>Effect of Coal Gasifier Pressure on H<sub>2</sub> Cost (\$/GJ, HHV)</b> <b>with CO<sub>2</sub> Co-Capture/Co-Storage</b>		
	70 bar	120 bar
Conventional technology	\$6.7/GJ (1265 MW <sub>h</sub> + 39 MW <sub>e</sub> )	\$6.6/GJ (1244 MW <sub>h</sub> + 51 MW <sub>e</sub> )
Pd/Cu membrane technology	\$6.7/GJ (1000 MW <sub>h</sub> + 18 MW <sub>e</sub> )	<b>\$6.2/GJ</b> (1000 MW <sub>h</sub> + 56 MW <sub>e</sub> )

- 70 bar desirable w/conv tech...obviates H<sub>2</sub> compression for pipeline transport...but only marginal potential incremental benefits at 120 bar
- **Higher pressures seem promising for dense metal membrane systems**
- Microporous membrane systems might benefit even more:  
H<sub>2</sub> flux ratio, microporous membrane/dense metal membrane  


$$\sim [(P_{h1} - P_{h2}) / (P_{h1}^{0.5} - P_{h2}^{0.5})] = (P_{h1}^{0.5} + P_{h2}^{0.5})$$

## Improving Efficiency, 70 bar Coal Gasifiers, Conv. Tech.

	Efficiency (HHV) for CO <sub>2</sub>		Cost for CO <sub>2</sub>	
	Vented	Cap/Stor	Vented	Cap/Stor
Electricity	$\eta_e = 100 * (\text{elect out}) / (\text{coal in})$		<i>(in ¢/kWh)</i>	
Quench	40.8	34.9	4.7	6.4
Syncooler	44.3	37.1	5.1	6.9
H <sub>2</sub>	$\eta_h = 100 * (\text{H}_2 \text{ out}) / [\text{coal in} - (\text{elect out} / \eta_e)]$		<i>(in \$/GJ, HHV)</i>	
Quench	69.7	67.0	6.2	7.3
Syncooler	72.9	69.6	7.0	8.3

- Efficiency improvement strategies for coal sometimes important (*e.g., cooled turbine for H<sub>2</sub> via membranes when electricity coproduct value high—will show*)
- But efficiency gains often not cost-effective (*coal prices low*)
- Syncoolers make less sense relative to quench for H<sub>2</sub> than for electricity ...though syncoolers for H<sub>2</sub> separation via membrane reactors merit attention
- For energy systems with CO<sub>2</sub> capture/storage, efficiency important only to extent that costs are reduced in climate-constrained world

## Membrane System with Cooled Raffinate Turbine



- Blade cooling enables higher TIT (1250 °C vs. 850 °C) and higher electrical conversion efficiency for raffinate stream. Requires much lower H<sub>2</sub> recovery factor (~60%) than for uncooled turbine (~ 85% H<sub>2</sub> recovery factor)...can be worthwhile if electricity value high

**Cooled vs. Uncooled Turbine for H<sub>2</sub> Manufacture (Pd/Cu membrane) @ 1 GW<sub>h</sub>, 120 bar Gasifier, Syngas Expander**


Turbine type	Electricity Coproduct	TIT	Cost of H <sub>2</sub> (\$/GJ) with CO <sub>2</sub> capture/storage for electricity @:	
			6.0 ¢/kWh	3.0 ¢/kWh
Uncooled	55 MW <sub>e</sub>	850 °C	\$6.2/GJ	\$6.6/GJ
Cooled	304 MW <sub>e</sub>	1250 °C	<b>\$4.8/GJ</b>	\$7.3/GJ

**Turbine cooling worthwhile if electricity prices are high**  
 ...e.g., if, under climate constraint, electricity is valued at cost for decarbonized coal IGCC

**Summarizing Outlook for Membrane Reactors**

- Co-capture and co-storage of SO<sub>2</sub> and CO<sub>2</sub> would probably be cost-effective...though viability of co-storage option requires clarification
- Increasing gasifier pressure (70 → 120 bar) raises system efficiency and offers potentially lower H<sub>2</sub> cost...if electricity coproduct has high value
- Using gasifiers with quench, potential cost reduction relative to “conventional technology”:
  - ~ 10% for dense metal (Pd/Cu) membranes
  - ~ 20% for microporous ceramic membranes (*but H<sub>2</sub> purity issues*)
  - Not larger potential savings because gas separation not large fraction of capital cost
- For future study:
  - microporous membranes with syncoolers and lower steam-to-carbon ratio
  - ion-transport membrane for O<sub>2</sub> production

### Coal/NG Competition in Electricity & H<sub>2</sub> Manufacture (for coal @\$1.2/GJ)



- NGCC for NG electricity (based on EPRI/DOE); FTR for NG H<sub>2</sub> (based on FW)
- H<sub>2</sub> from coal with CO<sub>2</sub> cap/stor competitive with H<sub>2</sub> from NG with CO<sub>2</sub> vented at much lower NG prices than for electricity
- Much lower carbon taxes needed to induce CO<sub>2</sub> cap/stor for coal than for NG.

### WHILE WAITING FOR A H<sub>2</sub> ECONOMY

- H<sub>2</sub> won't be widely used as energy carrier for at least 20-30 years
- But H<sub>2</sub> use in chemical/refining industries ~ 1% of global energy
- Gasification-based H<sub>2</sub> production at refineries/tar sands conversion plants (via gasification of coke, pitch) and NH<sub>3</sub> plants might be exploited as low-cost source of CO<sub>2</sub> for "megascale demonstration projects" of CO<sub>2</sub> storage in various geological media
  - Offering plant-gate CO<sub>2</sub> costs ≤ \$6/t (~ \$0.3/Mscf) gasification-based H<sub>2</sub> production plants often competitive even with natural CO<sub>2</sub> supplies for EOR projects
  - Are suitable CO<sub>2</sub> storage demo sites near prospective industrial H<sub>2</sub> production sites?
- Such demo projects might be considered for China as well as for industrialized countries in light of China's deep involvement with NH<sub>3</sub> production via gasification [China produces 5 million t/y of H<sub>2</sub> (98% at NH<sub>3</sub> plants) out of 40 million t/y worldwide]

### Plant-Gate CO<sub>2</sub> Costs with CO<sub>2</sub> Capture

Plant type	Plant output	CO <sub>2</sub> disposal rate (t/h)	Plant-gate CO <sub>2</sub> cost (\$/t)
NGCC (store) ( <i>from EPRI</i> )	311 MW <sub>e</sub>	118	58
Coal UCS (store) ( <i>from EPRI</i> )	367 MW <sub>e</sub>	335	33
NG H <sub>2</sub> (store) ( <i>from FW</i> )	1000 MW <sub>h</sub>	204	24
IGCC (store)	362 MW <sub>e</sub>	301	15.6
IGCC (co-store)	362 MW <sub>e</sub>	301	10.6
Coal H <sub>2</sub> (store), conv tech	1265 MW <sub>h</sub>	554	6.1
Coal H <sub>2</sub> (store), Pd/Cu memb.	1000 MW <sub>h</sub>	486	3.0
Coal H <sub>2</sub> (co-store), conv tech	1265 MW <sub>h</sub>	554	0.5
Coal H <sub>2</sub> (co-store), Pd/Cu memb.	1000 MW <sub>h</sub>	496	- 0.4

Costs for CO<sub>2</sub> coproduct of H<sub>2</sub> produced at refineries via petroleum residuals gasification would be similar to those for coal systems.

### Outlook for Fossil Fuel Competition in Power Markets in Climate-Constrained World

- IGCC favored technology for *new* coal power plants in climate-constrained world
- For IGCC, worthwhile to capture/store carbon @ CT ~ \$100/tC << than required to decarbonize NGCC
- Still, primary energy and generation cost penalties are significant for coal IGCC w/capture/storage (~ 16% and 35%, respectively)
- Not urgent to decarbonize new NGCC plants (*w/venting, emissions < 1/2 for IGCC*)
- At CT ~ \$100/tC, IGCC +CO<sub>2</sub> cap/stor cannot compete with NGCC + CO<sub>2</sub> venting—until P<sub>NG</sub> → \$6/GJ...or major IGCC capital cost reductions are realized
- Severe climate policy constraint → shift to NG at expense of coal for power → potential loss of coal energy infrastructure → deleterious long-term impact because of coal's promise in serving H<sub>2</sub> markets

### **Outlook for Fossil Fuel Competition in Making H<sub>2</sub> in Climate-Constrained World**

- As for electricity, needed  $(CT)_{\text{coal H}_2} \ll (CT)_{\text{NG H}_2}$  for inducing CO<sub>2</sub> capture/storage
- Primary energy and production cost penalties for capture/storage are much lower than for for coal IGCC (*~ 4% and 19%, respectively*)
- Unlike electricity, good prospects that coal H<sub>2</sub> w/capture/storage competitive with NG H<sub>2</sub> w/venting for  $P_{\text{NG}} \sim \$4.0/\text{GJ}$
- Making H<sub>2</sub> for energy is outstanding (*long-term*) opportunity for coal
- Transition to coal H<sub>2</sub> difficult because of market threat to coal power industry from NG in early years of transition to low C energy economy